

**Drinking Water Quality and Compliance  
SaskWater Buffalo Pound Potable Water Supply System - East  
2019 Notification to Consumers**

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the SaskWater Buffalo Pound Potable Water Supply System - East water quality and sample submission compliance record for the January 1, 2019 to December 31, 2019 time period. This report was completed on February 10, 2020. Readers should refer to WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

**BACTERIOLOGICAL QUALITY**

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	52	52	0
E. Coli	0 Organisms/100 mL	52	52	0
Background Bacteria	Less than 200/100 mL	52	52	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

**WATER DISINFECTION**

**Chlorine Residual in Distribution System – From Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.1 mg/L	0.41 – 1.22	0	52	52
Total Chlorine	0.5 mg/L	0.62 – 1.51	0	52	

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual **OR** 0.5 mg/L total chlorine residual is required at all times throughout the distribution system. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. Additional testing was done for informational purposes.

**Free Chlorine Residual for Water within the Distribution System**

Parameter	Limit (mg/L)	Range (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine
Free Chlorine	At least 0.1	0.21 – 2.01	Continuous	Continuous	100

Residuals are continuously monitored and recorded and tests performed by waterworks operators and are to be recorded in operation records.

**TURBIDITY**

**Turbidity in the Distribution System – From Test Results Submitted with Bacteriological Samples**

Parameter	Limit (NTU)	Range (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.06 – 0.45	0	52	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is reported in Nephelometric Turbidity Units (NTU). Additional testing was done for informational purposes.

**Buffalo Pound East Water Supply System**

**CHEMICAL – TRIHALOMETHANES (THM)**

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Trihalomethane	0.100 mg/L	0.051	4	4

Trihalomethanes are formed when chlorine reacts with organic matter in water. The four THM compounds are: chloroform, dibromochloromethane, bromodichloromethane (BCDM) and bromoform. The sum of the concentrations of these four components is referred to as Total Trihalomethanes. The limit for THM is a long term objective based on an annual average of seasonal samples.

**CHEMICAL – GENERAL**

The permit for SaskWater’s Buffalo Pound Potable Water Supply System – East does not require sampling for General Chemical parameters. Additional testing was carried out by SaskWater for informational purposes.

Parameter	MAC	AO*	Sample Results	# of Samples Required	# of Samples Submitted
Total Alkalinity (mg/L)		500	66.9	0	1
Bicarbonate (mg/L)	No Objective		82	0	1
Calcium (mg/L)	No Objective		24	0	1
Carbonate (mg/L)	No Objective		0	0	1
Chloride (mg/L)		250	20.6	0	1
Fluoride (mg/L)	1.5		0.07	0	1
Iron (mg/L)		0.3	<0.1	0	1
Total Hardness (mg/L)		800	142	0	1
Hydroxide (mg/L)	No Objective		0	0	1
Magnesium (mg/L)		200	20	0	1
Manganese (mg/L)		0.05	<0.01	0	1
Nitrate (mg/L)	45		0.2	0	1
pH (pH units)		6.5 - 9.0	6.9	0	1
Potassium (mg/L)	No Objective		5	0	1
Sodium (mg/L)		300	37	0	1
Specific Conductivity (µs/cm)	No Objective		481	0	1
Sulphate (mg/L)		500	125.8	0	1
Total Dissolved Solids (mg/L)		1500	315	0	1

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

\*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO<sub>3</sub>, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

**More information on water quality and sample submission performance may be obtained from:**

SaskWater  
 200 - 111 Fairford Street East  
 Moose Jaw SK S6H 1C8  
 Toll Free: 1-888-230-1111  
 Fax: 306-694-3207  
 Email: [customerservice@saskwater.com](mailto:customerservice@saskwater.com)