



**Drinking Water Quality and Compliance
SaskWater Edenwold Water Supply System
2019 Notification to Consumers**

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the SaskWater Edenwold Water Supply System water quality and sample submission compliance record for the January 1, 2019 to December 31, 2019 time period. This report was completed on February 10, 2020. Readers should refer to the WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water in Saskatchewan, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

BACTERIOLOGICAL QUALITY

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	52	52	0
E. Coli	0 Organisms/100 mL	52	52	0
Background Bacteria	Less than 200/100 mL	52	52	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

WATER DISINFECTION

Chlorine Residual in Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.1 mg/L	0.55 – 1.47	52	52	52
Total Chlorine	0.5 mg/L	1.17 – 2.40	52	52	

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual **OR** 0.5 mg/L total chlorine residual is required at all times throughout the distribution system. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.

Free Chlorine Residual for Water Entering Distribution System

Parameter	Limit (mg/L)	Range (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine
Free Chlorine	At least 0.1	0.37 – 2.00	365	Continuous	100

Residuals are continuously monitored and recorded. Tests are normally performed daily by waterworks operators and are to be recorded in operation records.

TURBIDITY

Turbidity in the Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Limit (NTU)	Range (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.11 – 1.20	52	52	0

Edenwold Water Supply System

Turbidity for Water Leaving the Filter

Parameter	Limit (NTU)*	Range (NTU)	95 th Percentile (NTU)	# Tests Required	# Tests Performed	# of Months Exceeding 95 th Percentile Limit
Turbidity	< 0.3 – 95% of measurements each month; not to be > 0.3 for > 12 consecutive hours; never >1.0	0.04 – 0.92	0.21	730	Continuous	1

The 0.3 NTU turbidity level requirement was exceeded in July of 2019. The level was below the 0.3 NTU requirement 92% of the time in July. The EPO is aware of the issue.

Turbidity in Water Entering the Distribution System

Parameter	Limit (NTU)	Range (NTU)	Average (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.02 – 2.00	0.21	365	Continuous	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU).

CHEMICAL – HEALTH

SaskWater’s Edenwold Water Supply System is required to submit water samples for the WSA’s Chemical Health category once every second year. 2019 is a required sampling year. Additional testing was carried out by SaskWater for informational purposes.

Parameter	MAC (mg/L)	IMAC (mg/L)	AO* (mg/L)	Sample Results (mg/L)	# of Samples Required	# of Samples Submitted
Aluminum	No Objective			<0.0161	1	2
Antimony	0.006			<0.00028	1	2
Arsenic	0.010			0.0023	1	2
Barium	1.0			0.0462	1	2
Boron		5.0		<0.1	1	2
Cadmium	0.005			<0.00015	1	2
Chromium	0.050			<0.00019	1	2
Copper			1.0	0.0219	1	2
Iron			0.3	<0.1	1	4
Lead	0.010			0.00035	1	2
Manganese			0.05	<0.01	1	4
Selenium	0.010			<0.00113	1	2
Silver	No Objective			<0.00020	1	2
Uranium	0.020			0.00040	1	2
Zinc			5	<0.0054	1	2

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

IMAC – Interim Maximum Acceptable Concentrations

CHEMICAL – TRIHALOMETHANES (THM)

Trihalomethanes are formed when chlorine reacts with organic matter in water. The four THM compounds are: chloroform, dibromochloromethane, bromodichloromethane (BCDM) and bromoform. The sum of the concentrations of these four components is referred to as Total Trihalomethanes. The limit for THM is a long term objective based on an annual average of seasonal samples.

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Trihalomethane	0.100 mg/L	0.053	4	4

Edenwold Water Supply System

CHEMICAL – HALOACETIC ACIDS (HAAs)

Haloacetic acids are formed when chlorine reacts with organic matter in water. The five regulated haloacetic acids are: monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid. The sum of the concentrations of these five components is referred to as HAA5. The limit for HAAs is a long term objective based on an annual average of quarterly samples.

Parameter	Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Haloacetic Acids 5	0.080	0.036	4	4

CHEMICAL – GENERAL

SaskWater’s Edenwold Water Supply System is required to submit water samples for the WSA’s General Chemical category once per three months every second year. 2019 is a required sampling year.

Parameter	MAC	AO*	Sample Results	# Of Samples Required	# Of Samples Submitted
Total Alkalinity (mg/L)		500	160	4	4
Bicarbonate (mg/L)	No Objective		195	4	4
Calcium (mg/L)	No Objective		115	4	4
Carbonate (mg/L)	No Objective		0	4	4
Chloride (mg/L)		250	81.0	4	4
Fluoride (mg/L)	1.5		0.08	4	4
Total Hardness (mg/L)		800	673	4	4
Hydroxide (mg/L)	No Objective		0	4	4
Magnesium (mg/L)		200	94	4	4
Nitrate (mg/L)	45		<0.2	4	4
pH (pH units)		6.5 - 9.0	7.6	4	4
Potassium (mg/L)	No Objective		29	4	4
Sodium (mg/L)		300	64	4	4
Specific Conductivity (µs/cm)	No Objective		1462	4	4
Sulphate (mg/L)		500	540.1	4	4
Total Dissolved Solids (mg/L)		1500	1117	4	4

MAC – Maximum Acceptable Concentration

AO – Aesthetic Objective

The aesthetic objective for Sulphate was exceeded, but all health regulatory requirements were met.

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards.

More information on water quality and sample submission performance may be obtained from:

SaskWater
 200-111 Fairford Street East
 Moose Jaw SK S6H 1C8
 Toll Free: 1-888-230-1111
 Fax: 306-694-3207
 Email: customerservice@saskwater.com