

**Drinking Water Quality and Compliance
SaskWater Buffalo Pound Potable Water Supply System - West
2020 Notification to Consumers**

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the SaskWater Buffalo Pound Potable Water Supply System - West water quality and sample submission compliance record for the January 1, 2020 to December 31, 2020 time period. This report was completed on January 28, 2021. Readers should refer to WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

BACTERIOLOGICAL QUALITY

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	24	52	0
E. Coli	0 Organisms/100 mL	24	52	0
Background Bacteria	Less than 200/100 mL	24	52	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks. Additional testing was done for informational purposes.

WATER DISINFECTION

Chlorine Residual within the Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.10 mg/L	0.42 – 1.22	24	52	52
Total Chlorine	0.50 mg/L	0.72 – 1.31	24	52	

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual **OR** 0.5 mg/L total chlorine residual is required at all times throughout the distribution system. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit. Additional testing was done for informational purposes.

Chlorine Residual for Water within the Distribution System

Parameter	Minimum Limit (mg/L)	Range (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine
Free Chlorine	0.10	0.33 – 1.64	Continuous	Continuous	100

Residuals are continuously monitored and recorded. Tests are performed by waterworks operators and are to be recorded in operation records.

Buffalo Pound West Water Supply System

TURBIDITY

Turbidity within the Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Limit (NTU)	Range (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.09 – 0.21	0	52	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is reported in Nephelometric Turbidity Units (NTU). Additional testing was done for informational purposes.

CHEMICAL – TRIHALOMETHANES (THM)

Parameter	Maximum Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Trihalomethane	0.100	0.036	4	4

Trihalomethanes are formed when chlorine reacts with organic matter in water. The four THM compounds are: chloroform, dibromochloromethane, bromodichloromethane (BCDM) and bromoform. The sum of the concentrations of these four components is referred to as Total Trihalomethanes. The limit for THM is a long term objective based on an annual average of seasonal samples.

CHEMICAL – HALOACETIC ACIDS (HAAs)

Haloacetic acids are formed when chlorine reacts with organic matter in water. The five regulated haloacetic acids are: monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid. The sum of the concentrations of these five components is referred to as HAA5.

Parameter	Maximum Limit (mg/L)	Average (mg/L)	# Samples Required	# Samples Submitted
Haloacetic Acids 5	0.080	0.024	4	4

CHEMICAL – HEALTH

The permit for SaskWater's Buffalo Pound Potable Water Supply System – West does not require sampling for Chemical Health parameters. Additional testing was carried out by SaskWater for informational purposes.

Parameter	MAC (mg/L)	IMAC (mg/L)	AO* (mg/L)	Sample Results (mg/L)	# of Samples Required	# of Samples Submitted
Aluminum	No Objective			0.0159	0	1
Antimony	0.006			<0.00016	0	1
Arsenic	0.010			0.0014	0	1
Barium	1.0			0.0481	0	1
Boron		5.0		0.1	0	1
Cadmium	0.005			<0.00015	0	1
Chromium	0.05			<0.00019	0	1
Copper			1.0	<0.00829	0	1
Iron			0.3	<0.1	0	1
Lead	0.01			0.00020	0	1
Manganese			0.05	<0.01	0	1
Selenium	0.01			<0.00113	0	1
Silver	No Objective			<0.00020	0	1
Uranium	0.02			0.00040	0	1
Zinc			5	<0.00400	0	1

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

IMAC – Interim Maximum Acceptable Concentrations

Buffalo Pound West Water Supply System

CHEMICAL – GENERAL

The permit for SaskWater's Buffalo Pound Potable Water Supply System – West does not require sampling for General Chemical parameters. Additional testing was carried out by SaskWater for informational purposes.

Parameter	MAC	AO*	Sample Results	# of Samples Required	# of Samples Submitted
Total Alkalinity (mg/L)		500	147	0	1
Bicarbonate (mg/L)	No Objective		179	0	1
Calcium (mg/L)	No Objective		45	0	1
Carbonate (mg/L)	No Objective		0	0	1
Chloride (mg/L)		250	36.0	0	1
Fluoride (mg/L)	1.5		0.11	0	1
Iron (mg/L)		0.3	<0.1	0	1
Total Hardness (mg/L)		800	215	0	1
Hydroxide (mg/L)	No Objective		0	0	1
Magnesium (mg/L)		200	25	0	1
Manganese (mg/L)		0.05	<0.01	0	1
Nitrate (mg/L)	45		<0.2	0	1
pH (pH units)		6.5 - 9.0	7.8	0	1
Potassium (mg/L)	No Objective		6	0	1
Sodium (mg/L)		300	44	0	1
Specific Conductivity (µs/cm)	No Objective		625	0	1
Sulphate (mg/L)		500	115.6	0	1
Total Dissolved Solids (mg/L)		1500	451	0	1

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

*Objectives apply to certain characteristics of or substances found in water for human consumptive or hygienic use. The presence of these substances will affect the acceptance of water by consumers and/or interfere with the practice of supplying good quality water. Compliance with drinking water aesthetic objectives is not mandatory as these objectives are in the range where they do not constitute a health hazards. The aesthetic objectives for several parameters (including hardness as CaCO₃, magnesium, sodium and total dissolved solids) consider regional differences in drinking water sources and quality.

More information on water quality and sample submission performance may be obtained from:

SaskWater
 200 - 111 Fairford Street East
 Moose Jaw SK S6H 1C8
 Toll Free: 1-888-230-1111
 Fax: 306-694-3207
 Email: customerservice@saskwater.com