

**Drinking Water Quality and Compliance
Town of White City
2020 Notification to Consumers**

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the Town of White City water quality and sample submission compliance record for the January 1, 2020 to December 31, 2020 time period. This report was completed on January 28, 2021. Readers should refer to the WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water in Saskatchewan, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

BACTERIOLOGICAL QUALITY

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	52	52	0
E. Coli	0 Organisms/100 mL	52	52	0
Background Bacteria	Less than 200/100 mL	52	52	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

WATER DISINFECTION

Chlorine Residual in Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.10 mg/L	0.21 – 1.15	0	52	52
Total Chlorine	0.50 mg/L	0.42 – 1.59	0	52	

A minimum of 0.10 milligrams per litre (mg/L) Free Chlorine residual **OR** 0.50 mg/L Total Chlorine residual is required at all times throughout the distribution system. An adequate chlorine residual is a result that indicates that the chlorine level is above the regulated minimums. Additional testing is done by Saskwater for informational purposes.

Free Chlorine Residual for Water Entering Distribution System

Parameter	Minimum Limit (mg/L)	Range (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine
Free Chlorine	0.10	0.53 – 1.25	366	Continuous	100

Residuals are continuously monitored and recorded.

Town of White City

TURBIDITY

Turbidity in the Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Limit (NTU)	Range (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.02 – 0.33	0	52	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU). Additional testing is done by Saskwater for informational purposes.

More information on water quality and sample submission performance may be obtained from:

Town of White City
PO Box 220
Station Main
White City SK S4L 5B1
Phone: 306-781-2355
Fax: 306-781-2194