

**Drinking Water Quality and Compliance  
Village of Edenwold Distribution System  
2023 Notification to Consumers**

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the Village of Edenwold water quality and sample submission compliance record for the January 1, 2023, to December 31, 2023 time period. This report was completed on February 1, 2024. Readers should refer to the WSA's Municipal Drinking Water Quality Monitoring Guidelines for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water in Saskatchewan, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>

**BACTERIOLOGICAL QUALITY**

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	12	12	0
E. Coli	0 Organisms/100 mL	12	12	0
Background Bacteria	Less than 200/100 mL	12	12	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

**WATER DISINFECTION**

**Chlorine Residual in Distribution System – From Test Results Submitted with Bacteriological Samples**

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.10 mg/L	0.37 – 0.75	12	12	12
Total Chlorine	0.50 mg/L	0.50 – 0.80	12	12	

A minimum of 0.10 milligrams per litre (mg/L) free chlorine residual **OR** 0.50 mg/L total chlorine residual is required at all times throughout the distribution system. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.

**Chlorine Residual for Water Within Distribution System**

Parameter	Minimum Limit	Range (mg/L)	# Tests Required	# Tests Submitted	% Adequate Chlorine
Free Chlorine	0.10 mg/L	0.32 – 1.45	Continuous	Continuous	100

Residuals are continuously monitored and recorded. Tests performed by waterworks operators are to be recorded in operation records.

***Village of Edenwold***

**TURBIDITY**

**Turbidity in the Distribution System – From Test Results Submitted with Bacteriological Samples**

<b>Parameter</b>	<b>Limit (NTU)</b>	<b>Range (NTU)</b>	<b># Tests Required</b>	<b># Tests Performed</b>	<b># Exceeding Limit</b>
Turbidity	No standard	0.08 – 0.45	0	12	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is generally reported in Nephelometric Turbidity Units (NTU). Additional testing done for informational purposes.

**More information on water quality and sample submission performance may be obtained from:**

Village of Edenwold  
P.O. Box 130  
Edenwold SK S0G 1K0  
Phone: 306-771-4121  
Fax: 306-771-2518